

VOC Content Test Certificate

Tuesday April 3rd, 2012

Supplier: Glue Guru Industrial Products (18 Kaimahi Rd, Wairau Valley, Auckland, NZ 0627)

Manufacturer: Quilosa Selena Iberia S.L.U. Centro Empresarial Rivas Futura, Marie Curie, 19
Planta 6.1, 28521 Rivas- Madrid, Spain

Sample Description: Quilosa Sintex MS-35

Date Tested: March 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in
Various Materials as referenced by South Coast Air Quality Management District
(SCAQMD) Rule 1168

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 & 3 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>Quilosa Sintex MS-35</p>
<p>Multipurpose construction adhesive 70 grams per Litre as VOC content per material</p>	<p>37 grams per Litre as VOC content per material</p>
<p align="center">NZ Green Building Council Green Star Office IEQ-3 Green Star Office Interiors IEQ-3 Green Star Industrial IEQ-3 Green Star Educational IEQ-3</p>	<p>Quilosa Sintex MS-35</p>
<p>Multipurpose construction adhesive 70 grams per Litre as VOC content per material</p>	<p>37 grams per Litre as VOC content per material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120308a